



Legislation Details (With Text)

File #: AUT 17-021 **Version:** 1 **Name:**
Type: Authorization **Status:** Agenda Ready
File created: 2/10/2017 **In control:** City Council
On agenda: 2/13/2017 **Final action:**
Title: Consideration of and action on emergency repairs of a 10" sewer force main located at Center Street and State Highway 225.

Sponsors:

Indexes:

Code sections:

Attachments:

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

Consideration of and action on emergency repairs of a 10" sewer force main located at Center Street and State Highway 225.

Summary:

Due to the deterioration and failure of approximately 270 linear feet of 10" sewer force main repairs will made by Vaught Services by pipe bursting rehabilitation method. The existing cast iron sewer line was installed in 1970.

Fiscal/Budgetary Impact:

To be provided at the meeting.

Approval of repairs