



Legislation Text

File #: AUT 17-021, **Version:** 1

Consideration of and action on emergency repairs of a 10" sewer force main located at Center Street and State Highway 225.

Summary:

Due to the deterioration and failure of approximately 270 linear feet of 10" sewer force main repairs will be made by Vaught Services by pipe bursting rehabilitation method. The existing cast iron sewer line was installed in 1970.

Fiscal/Budgetary Impact:

To be provided at the meeting.

Approval of repairs