



Legislation Text

File #: AGR 19-039, **Version:** 1

Consideration of and action on entering into an agreement with Ardurra Group, LLC for engineering services for installation of residual control systems at the P Street and Avon sites.

Summary: Residual Control Systems have been added to the Coy Drive and Pasadena sites which have improved the water quality at the location and in the distribution system around the tanks. The P Street and Avon sites are the next sites scheduled to get these improvements so that the water is continuously monitored, the chemical is only injected when needed and we have the ability to add both chlorine and ammonia.

This agreement is for the engineering services associated with the project. It includes a review of the records drawings and related design documents of the pump stations, coordination with city and RCS manufacturer to develop basis of design, construction plans, and specifications for installation, submit all needed documents to TCEQ and confirm performance of the system after it has been commissioned.

The total cost is \$53,760.00.

Fiscal/Budgetary Impact:

The project is budgeted from account 400-503-4904 for additional PAX Units.

Staff recommends entering into the agreement with Ardurra Group, LLC.